

# Emission Test Certificate

Wednesday, 04<sup>th</sup> July 2018

Supplier: The Laminex Group Technology Centre (21 Trewin Street, Wendouree, VIC, 3355)

Sample Description: Melteca Acrylic Soft Touch

Date Tested: June 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-17 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Materials/Products”.

Emission Data (7 days exposure):

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built v1.1 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.1 - 12.1.2B</b></p>	<p align="center"><b>Melteca Acrylic Soft Touch</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate limit &lt;0.5 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.026 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant



Tuan Duong  
B Eng. (Chem.)  
Consultant

**CV180618A**